

R

TO: DAVID L. NARVER, JR. JOB: 884 O/S 6477

FROM: R. A. BOETTCHER RE: SUBSTATION EE-411 - ELMER

DATE: 17 JULY 1953

References: 1. 3230-EE-6

2. 5203-EE-9

To avoid conflict with fresh and salt water lines shown on Reference 2, a new location has been selected in the field for the subject substation. The center of the substation is now located 17-1/2 feet from Pole F7D, normal to the pole line, and 3-1/2 feet toward Pole F7C.

Closer checking of drawings before they are issued is requested, to prevent recurrence of similar conflicts in future designs.

R. A. Boettcher.

RAB:jws

R. A. BOETTCHER
RESIDENT ENGINEER

cc: S. P. Howell
HO Chrono
HO Central
OS Chrono
OS Central
OS Engineering (Elec.)

REPOSITORY NATIONAL ARCHIVES
PACIFIC SOUTHWEST REGION
COLLECTION RG 326 ATOMIC ENERGY COMMISSION
BOX No. 199624 (#608) A16334 326-65V0170
ELMER GENERAL
FOLDER JCB 884 PROJECT ENGINEERING FILE



7044